

CALCULATION COVER SHEET

PROJECT CO2 KARSTO	JOB NO. 25474	CALC NO. Bechtel:25474-000-M4C-CN-00004 Owner:10112936-PB-P-TDO-0004	SHEET 1
SUBJECT: Stripper sizing calculations		DISCIPLINE: Process	

CALCULATION STATUS	PRELIMINARY X	CONFIRMED	SUPERSEDED	VOIDED	
--------------------	------------------	-----------	------------	--------	--

COMPUTER PROGRAM/TYPE	SCP		MAINFRAME PC		PROGRAM NO.	VERSION/ RELEASE NO.
	YES	NO	YES	NO	Promax KG-TOWER Sulcol	2 3.2 1.05
		X	YES	X		

Use of these calculations by persons, without access to pertinent factors and without proper regard for their purpose, could lead to erroneous conclusions. Should it become necessary to use any of these calculations in your work in the future, it is suggested that the calculations be reviewed with authorized Bechtel personnel to ensure that the purposes, assumptions, judgments and limitations are thoroughly understood. Bechtel cannot assume responsibility for the use of these calculations not under our direct control.

- Reference Data: 1.**
- 1) Bechtel Process Engineering Design Guide - Tower Internals
 - 2) Bechtel Standard Drawing No. B-501,B505,B503,B-504
 - 3) Bechtel Process Engineering Design Guide - Separators
 - 4) Heat & Material Balance Normal Case

Design Basis: CO2 Kårstø - Exhibit E0 - Design Basis

Remarks:
This document provides the sizing calculation for Stripper.

Comments

1	Issued For Information Including Comments <i>P0046</i>	7	7	MJC	HS/DM	ADB/BR	12-Nov-08
0	Issued For Deliverable Milestone Schedule M2	7	7	HS	MJC/DM	ADB/BR	08-Oct-08
NO.	REASON FOR REVISION	TOTAL NO. OF SHEETS	LAST SHEET NO.	BY	CHECKED	APPROVED/ ACCEPTED	DATE
RECORD OF REVISIONS							



CALCULATION SHEET

CALC NO. Bechtel:25474-000-M4G-CN-00004 Owner:10112936-PB-P-TDO-0004
 SUBJECT MJC DATE 12/Nov/08 CHECKED HS DATE 12/Nov/08
 PROJECT CO2 KARSTO JOB NO. 25474
 SUBJECT Stripper sizing calculations SHEET 2 OF 7 SHEETS

1. PURPOSE OF CALCULATION:

Sizing of the CO2 Stripper, MV-103 based on the design basis and bechtel standard guides

2. METHODOLOGY:

Heat and material balances developed for Normal reclaim and without reclaim operation by Bantrel were used in this calculation. Column Diameter was calculated using two programs KG tower and Sulcol. Using conservative approach larger diameter was used to fix the diameter of the column.

These have been reviewed against the final Normal, Winter and Summer cases and where more conservative values have been taken from these cases. Turndown of 60% on design values is required and achievable.

The height of the column was worked out based on:

Residence time of 5 mins for lean amine in column bottom (LLL - HLL).

Surge Volume provided for 5% of packing volume on draw-off tray.

3. COLUMN DIAMETER:

3.1 Software calculation

Basis of flows for diameter calculation

TRAY SECTION

	Flow kg/hr	Mol wt	Density kg/m3	Viscosity cp	Surface tension Dynes/cm		
Vapour	214663	28.4	1.8				
Liquid	8495	19.1	964.7	0.297	56.1		

PACKING SECTION

	Flow kg/hr	Mol wt	Density kg/m3	Viscosity cp	Surface tension Dynes/cm		
Vapour	205057	20.3	1.429				
Liquid	2292100	25.3	1074.6	0.506	47.1		

The results of the KG-Tower and Sulcol are tabulated below:

Packing Section

Program	Column Tag No.	Diameter mm	Internals	Flooding Limit %	System Factor	HETP Height m
KG Tower	MV-103	#	FLEXIPAK 250 YHC structure packing	0.8	0.85	2.0
Sulcol	MV-103	#	Mellapak 170X structure packing	0.8	0.85	2.0

Tray Section

Program	Column Tag No.	Diameter mm	Internals	Flooding Limit %	System Factor	Spacing mm
KG Tower	MV-103	#	Type-T,A-2	0.8	1.0	600.0
Sulcol	MV-103	#	MMVG	0.8	1.0	600.0

- values obtained from vendor software and subject to confidentiality agreement between Bechtel and vendor

Selected the largest column diameter 6665 mm say 6670 mm

3.1 Reboiler Configuration

The chimney drawoff tray collects all liquid from the packing above and directs it to the bottom of the reboiler sump where it is preferentially directed to the reboiler(s). Liquid from this sump flows through the reboilers by gravity and the two-phase reboiler outlet stream returns to the stripper. Reboiler vapor separates and flows up through the chimney tray into the packing. Excess liquid in the reboiler sump overflows the weir at the top of the reboiler sump and into the pumpout sump where it is pumped out as lean amine. This design is more stable in operation than a once-through reboiler configuration, and handles stripper turndown and/or variations in reboiler performance (fouling) very well. Mechanical details of the reboiler sump and the configuration of the reboiler return nozzles will be developed during detailed design after final vendor data is available on number and configuration of reboiler units.





CALCULATION SHEET

CALC NO. Bechtel:25474-000-M4C-CN-00004 Owner:10112936-PB-P-TDO-0004
 SUBJECT MJC DATE 12/Nov/08 CHECKED HS DATE 12/Nov/08
 PROJECT CO2 KARSTO JOB NO. 25474
 SUBJECT Stripper sizing calculations SHEET 3 OF 7 SHEETS

4. COLUMN HEIGHT:

4.1 Liquid Levels:

Flow Rate 22709.18 kg/h
 Density 1062 kg/m³
 Volume Flow 2137 m³/h
 Column Diameter 6.67 m
 CSA 34.9 m²

The reboiler feed sump is assumed to occupy 17% of the column cross-sectional area, so 6 minutes sump provides 1min to reboiler and 5 mins to amine pump suction

	Calculated mm	Actual mm	Vol (m ³)	Hold up Vol (m ³)	Hold up min	
HHLL (from BTL)	8456	8500	295.5	35.6	1	1 min holdup time between HHLL and HLL
HLL (from BTL)	7437	7500	259.8	213.7	6	6 minutes required (see note above)
NLL (from BTL)	4378	4425	153.0	178.1		
LLL (from BTL)	1320	1350	46.1	35.6	1	1 min holdup time between LLLL and LLL
LLLL (from BTL)	300	300	10.5			



4.2 Liquid Levels on Draw-Off Tray:

Vapor Flow Rate 20008.8 kg/h
 Density 3738 kg/m³
 Volume Flow 145646 m³/h
 Column Diameter 6.67 m
 CSA Tower 34.9 m²
 Chimney area= % of X-sec area 20%
 Total X-sectional Chimney area 7.0 m²
 Diameter of 1 chimney 3.0 m
 Velocity through total chimney area 5.79 m/s

The current internals configuration is for liquid to be collected in the reboiler sump at the bottom of the column. The following dimensions are calculated to provide sufficient column height for alternative reboiler configurations to be implemented later if desired.

(Bantrel B-501-SI, note 2)

Limiting the chimney diameter to 1.0 m
 CSA per chimney 0.785 m²
 Clearance b/t plate and chimney to limit the gas velocity to 5.79 0.250 m

(9 Chimneys)

clearance= vapor exit area = chimney area (Bantrel B-501-SI, note 3)

Height above chimney 0.75 m
 Stream to reboiler 144157.0 kg/h
 Density 1067.8 kg/m³
 Volume Flow 1350 m³/h

min. 12" Bantrel B-504-IMP or 0.75 dr (Stream 318)

Chimney height = Buffer volume
 5% of packed volume 34.94 m³
 Total chimney height 1250 mm

Provide space for alternative reboiler arrangement with 2 draw-off nozzles from draw-off tray



Min Depth of Pan
 Based on 2 x N7 Nozzle size = 600NS 762 mm

Bechtel Standard 3DG-B10-017, page 68, 30" for 24" nozzle



CALCULATION SHEET

CALC NO. Bechtel:25474-000-M4C-CN-00004 Owner:10112936-PB-P-TDO-0004
 SUBJECT MJC DATE 12/Nov/08 CHECKED HS DATE 12/Nov/08
 PROJECT CO2 KARSTO JOB NO. 25474
 SUBJECT Stripper sizing calculations SHEET 4 OF 7 SHEETS

4.3 Column

Height		667	mm	> 305 mm or 10% D	Bantrel B-505-SI	
		150	mm	Allowance for Demister		
Nozzle N2	50.8					
Manway 30"		762				
Liquid distributor						
From Distributor to Tray 1		600	mm			
Tray 1-3		1200	mm			
Nozzle N3	609.6					
Manway 30"		762				
From Tray3 to Bed 1		1500	mm			
Bed 1 height		4000	mm			
Nozzle N4	254					
Manway 30"		762				
From Bed 1 to Bed 2		1500	mm			
Bed 2 height		8000				
Bed 2 support	600					
From Bed 2 to Bed 3		1500				
Bed 3 height		8000	mm			
Bed 3 support		500	mm	Assumed		
Manway 30"	762				trayspacing +152 B-503-SI	
Bed 3 to N11		752				
Nozzle N11 A/B		254				
Height above chimney		750	mm	min. 12" Bantrel B-504-IMP or 0.75 dr		1
Clearance between plate and top		250	mm			
Height of chimney		1250				
Depth of Pan		762	mm			
Pan not required for presented reboiler configuration						
height above N6 to tray		854			trayspacing +152 B-503-SI + 102 margin	1
Nozzle N5	254.00					
Nozzle N6		1219				
Nozzle N7	762					
Height above HHLL		610	mm	B-503-SI 305+305		
Height for level control		8500	mm			
Total height (T/T)		23580	mm			



CALCULATION SHEET

CALC NO. Bechtel: 25474-000-M4C-CN-00004 Owner: 10112936-PB-P-TDO-000
 SUBJECT MJC DATE 12/Nov/08 CHECKED HS DATE 12/Nov/08
 PROJECT CO2 KARSTO JOB NO. 25474
 SUBJECT Stripper sizing calculations SHEET 5 OF 7 SHEETS

5.0 Column Tray Efficiencies:

	Theoretical Stages	HETP/ No of Trays per stage	Height m
Trays	1	3.00	1.2
Packed	10	2.00	20.0

Column Packing Section

Bed 1	4000 mm	Stage 2+3
Bed 2	8000 mm	Stage 4-7
Bed 3	8000 mm	Stage 8-11

6.0 Pressure Drops:

Pressure Drop through Packed beds	1.65	mbar/m
Total Height of Packed Beds	20	m
Total Pressure drop	33	mbar
Pressure Drop through 1 tray	5.1	mbar

	Mass flow (Kg/hr)	Density (Kg/m ³)		Velocity (m/s)	Pressure	
		Liquid	Gas		Drop	
outlet nozzle	214013		1.79	40.96	0.751	kPa
Top Trays drop	214013		1.79		1.530	kPa
Chimney Tray	0		0.00	5.79	0.000	kPa
Packed Bed	214013		1.79		3.300	kPa
liquid distributor	214013.00		1.79	0.95	0.003	kPa
ΔP					5.584	kPa



CALCULATION SHEET

CALC NO. Bechtel:25474-000-M4C-CN-00004 Owner:10112936-PB-P-TDO-0004
 SIGNATURE MJC DATE 12-Nov-08 CHECKED HSS DATE 12-Nov-08
 PROJECT CO2 KARSTO JOB NO. 25474
 SUBJECT Stripper sizing calculations SHEET 6 OF 7 SHEETS

7.0 Nozzle Sizes.

N1: Vapor Outlet nozzle

Case	Normal Flow / No Margin		
Flow (Stream 320)	214013.0 KG/HR		
Density	1.79 KG/M ³		
Nozzle Diameter	40.00 IN	1016 mm	
No of nozzles	1.00		
Velocity	40.96 M/S		
	134.40 FT/S		50-150 ft/s
rv2	3003.7770 Pa		


N2: Reflux

Case	Normal Flow / No Margin		
Flow (Stream 322)	7321.2 KG/HR		
Density	988.48 KG/M ³		
Nozzle Diameter	2.00 IN	50.8 mm	
No of nozzles	1.00		
Velocity	1.02 M/S		
	3.33 FT/S		5-10 ft/s


N3 A/B: Rich Amine (Mixed Phase)

Case	Normal Flow / No Margin	WL	2189943.0
Flow (Stream 302)	2283100.0 KG/HR	Wg	37967.0
Density	98.10 KG/M ³	rho L	1124.6
Nozzle Diameter	24.00 IN	609.6 mm rho	2.046
No of nozzles	2.00		108.6
Velocity	11.07 M/S		
	36.34 FT/S		25-45 ft/s
rv2	12032.5111 Pa		

N4: Flash Gas

Case	Normal Flow / No Margin		
Flow (Stream 312)	9550.1 KG/HR		
Density	2.12 KG/M ³		
Nozzle Diameter	10.00 IN	254 mm	
No of nozzles	1.00		
Velocity	24.73 M/S		
	81.15 FT/S		50-150 ft/s
rv2	1294.9555 Pa		

N5: Amine from reclaimer

Case	Normal Flow / No Margin		
Flow (Stream 317A)	13850.0 KG/HR		
Density	1.66 KG/M ³		
Nozzle Diameter	10.00 IN	254 mm	
No of nozzles	1.00		
Velocity	45.66 M/S		
	149.80 FT/S		50-150 ft/s

N6 A-D: Reboiler Return

Case	Normal Flow / No Margin		
Flow (Stream 314+319)	1441370.0 KG/HR		
Density	9.82 KG/M ³		
Nozzle Diameter	48.00 IN	1219.2 mm	
No of nozzles	4.00		
Velocity	8.73 M/S		
	28.65 FT/S		25-45 ft/s


N7: Reboiler inlet stream

Case	Normal Flow / No Margin		
Flow (Stream 318)	1441370.0 KG/HR		
Density	1067.80 KG/M ³		
Nozzle Diameter	30.00 IN	762 mm	
No of nozzles	1.00		
Velocity	0.82 M/S		
	2.70 FT/S		<4 ft/s

N8: To P-105A/B

Case	Normal Flow / No Margin		
Flow (Stream 314)	2270917.9 KG/HR		
Density	1062.47 KG/M ³		
Nozzle Diameter	36.00 IN	914.40 mm	
No of nozzles	1.00		
Velocity	0.90 M/S		
	2.97 FT/S		2-4 ft/s

N11 A/B: Vent Steam from flash tank

Case	Normal Flow / No Margin		
Flow (Stream 527, winter case)	5515.0 KG/HR		
Density	1.23 KG/M ³		
Nozzle Diameter	10.00 IN	254 mm	
No of nozzles	2.00		
Velocity	12.29 M/S		
	40.32 FT/S		50-150 ft/s
rv2	185.7831 Pa		



CALCULATION SHEET

CALC NO. Bechtel: 25474-000-MAC-CN-00004 Owner: 10112936-PB-P-TDO-0
 SUBJECT: MJC DATE: 12/Nov/08 CHECKED: HS DATE: 12/Nov/08
 PROJECT: CO2 KARSTO JOB NO.: 25474
 SUBJECT: Stripper sizing calculations SHEET: 7 OF: 7 SHEETS

8.0 Sketch

STRIPPER COLUMN
 TL: TL = 43,580 mm
 ID = 6,670 mm

