



- NOTES:
1. FOR SYMBOLS AND LEGENDS SEE DRAWINGS M6J-YA-00001 THROUGH M6J-YA-00005.
 2. ALL LINES, VALVES, EQUIPMENT, AND INSTRUMENT NUMBERS ARE PREFIXED WITH "SB", UNLESS NOTED OTHERWISE.
 3. ALL VENTS, DRAINS AND INSTRUMENTATION ROOT VALVES ARE 1", UNLESS NOTED OTHERWISE.
 4. * SYMBOL INDICATES EQUIPMENT SUPPLIED BY VENDOR.
 5. VENT TO SAFE LOCATION, MIN 3M. ABOVE GRADE.

Bechtel Confidential
 BECHTEL POWER CORPORATION 2008. ALL RIGHTS RESERVED. BECHTEL CONFIDENTIAL. CONTAINS INFORMATION THAT IS CONFIDENTIAL AND PROPRIETARY TO BECHTEL AND MAY NOT BE USED, REPRODUCED OR DISCLOSED IN ANY FORMAT WITHOUT BECHTEL'S PRIOR WRITTEN PERMISSION. THIS DOCUMENT IS PREPARED EXCLUSIVELY FOR GASSNOVA IN CONNECTION WITH THE PREPARATION OF THE FEED STUDY FOR THE CO2 CAPTURE FACILITY AT KARSØ, NORWAY, AND IS NOT TO BE RELIED UPON BY OTHERS OR USED IN CONNECTION WITH ANY OTHER PROJECT.

NO.	DATE	ISSUED FOR APPROVAL	BY	CHK	MECH SUPV	CS SUPV	PI SUPV	PROJ ENGR
13	11/11/11	ISSUED FOR APPROVAL	WJ	HS	HS	HS	HS	HS

BECHTEL POWER CORPORATION
 FREDERICK, MARYLAND

CO2 KARSTO PROJECT

PIPING & INSTRUMENT DIAGRAM
 AUXILIARY BOILER SYSTEM

GASSNOVA	OWNER DOCUMENT NUMBER	10112936-PB-P-PID-0060	JOB NO.	25474-000	DRAWING NO.	M6-SB-00001	REV	0
----------	-----------------------	------------------------	---------	-----------	-------------	-------------	-----	---

LEVELS 111111111 122222222 333333333 333344444 444555555 555566666
 1.2345678901.2345678901.2345678901.2345678901.2345678901.2345678901.2345678901.23

6

5

4

3

A R I 2

D
C
B
A