



- NOTES:
- FOR SYMBOLS AND LEGENDS SEE DRAWINGS M6J-YA-00001 THROUGH M6J-YA-00005.
  - ALL LINES, VALVES, EQUIPMENT, AND INSTRUMENT NUMBERS ARE PREFIXED WITH "CN", UNLESS NOTED OTHERWISE.
  - ALL VENTS, DRAINS AND INSTRUMENTATION ROOT VALVES ARE 1", UNLESS NOTED OTHERWISE.
  - HEAT TRACE BOTTOM OF STRIPPER COLUMN UP TO THE HIGH-HIGH LIQUID LEVEL.
  - FOUR NOZZLES FROM E-110 PLACED AROUND COLUMN DIAMETER, SAME HEIGHT. LINE SIZE AND CONFIGURATION TO BE FINALIZED DURING DETAILED ENGINEERING.
  - SYMMETRICAL PIPING

- HOLDS:
- CONTROL VALVE AND PRESSURE SAFETY VALVE SIZES.

T-103  
STRIPPER  
(PACKED SECTION)

FOR CONTINUATION  
SEE M6-CN-00130

HHLL 8500 MM  
HLL 7500 MM  
NLL 4425 MM  
LLL 1350 MM  
LLLL 300 MM

EL. 5000 MM

©Bechtel Corporation 2008. All rights reserved. Bechtel, Confidential. Contains information that is confidential and proprietary to Bechtel and may not be used, reproduced, or disclosed in any format without Bechtel's prior written permission. This document is prepared exclusively for the use of the CO2 Capture Facility at Karsto, Norway, and is not to be relied upon by others or used in connection with any other project.

		ISSUED FOR APPROVAL		GR	UP	-	RS	APPR
NO.	DATE	REVISIONS		BY	CHK	DES	ENGR	PRGR
10112936-PB-P-PID-0023		GASSNOVA		CO2 KARSTO PROJECT				
PIPING & INSTRUMENT DIAGRAM AMINE STRIPPER (PACKED SECTION)		Scale: N.T.S.		SHEET NO. 25474				
BECHTEL POWER CORPORATION FREDERICK, MARYLAND		JOB NO. 000-M6-CN-00120		DRAWING NO.		REV. 0		