



# Calculation Cover Sheet

Subject Short-Circuit Calculations  
 Discipline Electrical

Project KARSTO  
 Job No. 25474-000  
 Calc. No. 25474-000-E0C-ES-00002  
 Sheet 1 of 9

Calculation Status Designation	Preliminary	Confirmed with Preliminary Information	Confirmed	Superseded	Voided
	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Computer Program/Type	SCP	Program Name.	Version/Release	Operating System
	<input checked="" type="checkbox"/>	ETAP	6.0.0	Windows XP

Nuclear Quality Classification	Safety-Related	Augmented Quality	Nonsafety-Related
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Use of these calculations by person, without access to pertinent factors and without proper regard for their purpose, could lead to erroneous conclusions.

Should it become necessary to use these calculations in your work in the future, it is suggested that the calculations be reviewed with authorized Bechtel personnel to ensure that the purposes, assumptions, judgments and limitations are thoroughly understood. Bechtel cannot assume responsibility for the use of these calculations not under our direct control.

Owner Document No. 10112936-PB-E-TDO-0002

Rev. No.	Reason for Revision	Total No. of Sheets	Last Sheet No.	By	Checked	Approved/ Accepted	Date
0	Issued for Comment	21	Attachment 5, Sheet 1 of 1	VS	WK	<i>Bm</i> SMS	11/2/08
<b>Record of Revisions</b>							



# CALCULATION SHEET

Project: Karsto

Subject: Short-Circuit Calculations

Job Number: 25474

Calculation No25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 2

Sheet Rev. 0

## Contents

<u>Section</u>	<u>Page</u>
<b>1.0 Scope</b>	<b>3</b>
<b>2.0 Methodology</b>	<b>4</b>
<b>3.0 Assumptions and Settings</b>	<b>4</b>
<b>4.0 Calculations</b>	<b>6</b>
<b>5.0 Conclusions</b>	<b>8</b>
<b>6.0 List of Attachments</b>	<b>8</b>



## CALCULATION SHEET

Project: Karsto

Subject: Short-Circuit Calculations

Job Number: 25474

Calculation No 25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 3

Sheet Rev. 0

### Short-Circuit Calculations

#### 1.0 SCOPE

The scope of this Report includes a review and analysis of the electrical power system for the CO<sub>2</sub> Capture and Compression (CCC) facility adjacent to the gas-fired Combined Cycle Power Plant (CCPP) at Kårstø in the South-West of Norway. An electrical model was developed and various studies were conducted as a preliminary investigation of the power system performance to determine sizes and ratings of the major electrical equipment based on the system information available at this stage of the project. In order to complete these calculations some assumptions were made which are explained later in this report.

The 22kV Substation located in CCC facility is supplied with 20kV (Feeder A) and 6.6kV (Feeder B) in-feeds from the CCPP 20kV Generator Isophase Bus and 6.6kV Switchgear 10BBE through power transformers CCC FACILITY XFMR 1ESETP01 (50MVA, 20-23kV) located in CCPP facility and DEAD TIME XFMR 1ESETP02 (3MVA, 6.6-23Kv) located outdoor in the CCC facility. The 22kV Switchgear (1ESESI01) 22kV-SWGR is indoor switchgear with manual bus transfer arrangement. The voltage is further stepped down to 6.6kV and 400V distribution levels to feed various loads. Additionally, three large motors (compressor and blowers) are supplied from 22kV-switchgear (1ESESI01) via isolation transformers and controlled through adjustable speed drive systems (ASDS).

The purpose of Short-Circuit (SC) Calculations is to:

- Determine fault currents expected at different parts of the electrical system under various operating conditions.
- Determine maximum and minimum SC Currents under various fault conditions
- Establish electrical equipment's momentary rating (mechanical requirements of bus bracing) and short circuit interrupting capability.
- Determine spare SC capacity per main switchgear
- Determine transformer sizes and impedances.

Calculations reflect the most unfavorable operation and the pessimistic equipment parameter assumption.



## CALCULATION SHEET

Project: Karsto

Subject: Short-Circuit Calculations

Job Number: 25474

Calculation No 25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 4

Sheet Rev. 0

### 2.0 METHODOLOGY

The electrical model was developed using ETAP PowerStation (Version 6.0.0) software based on Load List and Single Line Diagrams (SLD) as available at time of calculations and the system information provided by GASSNOVA as Owner and FICHTNER as Owner's Engineer.

For equipment withstanding rating, the maximum fault currents that equipment can be subjected to must be defined. ETAP PowerStation calculates maximum faults when study is run using "Balanced System Study (IEC-60909)" function, calculation Method "C" for X/R peak kA. It calculates peak fault currents, symmetric sub-transient and steady RMS fault currents for 3-phase, phase-to-phase (L-L), phase-to-earth (L-G), phase-to-phase-to-earth (L-L-G) faults. These faults values are used to determine bus bracing requirements and equipment fault interrupting capability.

Calculation cases comprise various scenarios to evaluate options and limitations pertaining to operation of the distribution system under different conditions.

For all calculations, Normal system configuration is when Feeder A in-feed breaker is closed and Feeder B in-feed breaker is open and Low Voltage Switchgear (400V-LdCntr) tie-breaker is open and in-feeds breakers closed. Alternate configurations are when Feeder A in-feed breaker is open and Feeder B in-feed breaker is closed (Stand by Mode) and for 400V-LdCntr in-feed breaker B is open and tie-breaker and in-feed breaker A are closed. For reference the SLDs are listed in Section 6.0.

### 3.0 ASSUMPTIONS AND SETTINGS

The following are detailed descriptions of connections, conditions and equipment assumed for the calculations. Single Line Diagrams using ETAP PowerStation are listed in Section 6.0 ATTACHMENTS.

- 50 MVA Power Transformer Data and 22kV 22kV-SWGR data was provided by FICHTNER as follows:
  - Power transformer connected to the external grid, 50 MVA , 20/23kV, 12.5% impedance, provided by others
  - 22kV switchgear shall be designed for  $I_b(\text{sym})=31.5\text{kA}$ ,  $I_p=80\text{kA}$
- The estimated available short circuit currents at CCPP switchgear 10BBE were provided by FICHTNER as follows:
  - Minimum available SC is 8kA
  - Maximum available SC is 25kA
- Assumed X/R ratio for Min/Max SC on CCPP switchgear 10BBE is 50.



## CALCULATION SHEET

Project: Karsto

Subject: Short-Circuit Calculations

Job Number: 25474

Calculation No 25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 5

Sheet Rev. 0

- The estimated available short circuit currents at the primary side of the 50 MVA transformer were provided by FICHTNER as follows:
  - Minimum available SC is 60kA
  - Maximum available SC is 130kA
- 6.6kV SWGR shall be designed for  $I_b(\text{sym})=31.5\text{kA}$ ,  $I_p = 80\text{kA}$
- 0.4kV Load Center shall be designed for  $I_b(\text{sym})= 100\text{kA}$ ,  $I_p = 220\text{kA}$
- 0.4kV MCC shall be designed for  $I_b(\text{sym})= 75\text{kA}$ ,  $I_p = 165\text{kA}$
- Assumed X/R ratio for Min/Max SC on the primary side of the 50 MVA transformer is 95.
- Transformers sizes were considered as shown on the single line diagrams. Actual data was used for transformer impedances where known, otherwise typical data used where unknown.
- Transformer Impedance negative tolerance is considered in calculations as - 7.5%
- Transformer sizing was checked by ETAP based on IEC standard, connected loads, operating load and ambient temperature 40° C.
- Symbols for two-winding VFD transformers (T1, T2, and T3 on SLD) only for reference purpose and will be defined later by VFD Vendor.
- Voltage tolerance of the 20kV and 6.6kV upstream Owner provided utility systems is estimated as +/- 2%.
- For maximum short-circuit calculations pre-fault voltage of 1.1 p.u. will be used for conservative results.
- For minimum short-circuit calculations pre-fault voltage of 0.95 p.u. will be used for conservative results.
- All loads are based on Load List and Single Line Diagram.
- 50MVA CCC Facility transformer tap set to 0% and all other power transformers tap set to +2.5% on primary.
- Short-Circuit calculations are based on motor "status" (spare motors do not contribute).
- 11kV Motors do not contribute to short circuit current via ASDs (VFDs)
- Ambient temperature for A/G trays is 40° C and for U/G Ducts is 20° C. Cables temperature range is from 20° C to 80° C.
- Cable Loading factors are from 1 to 1.35 for different loads according to IEC.



## CALCULATION SHEET

Project: Karsto

Subject: Short-Circuit Calculations

Job Number: 25474

Calculation No 25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 6

Sheet Rev. 0

- Cable calculations assume short-circuit protection clearing time of 0.1second.
- Cable grouping was assumed as per Exhibit E5.7- Cabling and Cable Trays.
- Cable sizing was verified by ETAP based on ICEA P-54-440 standard for above ground (A/G) tray installations and IEEE 399 standard for under ground (U/G) duct installations.
- Load category is "design" and assumed 100% of nameplate rating for pessimistic results.
- Cable Sizes are as shown on the SLD. Cable impedance values are typical as listed in the ETAP PowerStation cable library.

### **4.0 CALCULATIONS**

Two Short Circuit Study cases were run based on operating conditions of the downstream system as follows:

#### **4.1 CASE 1: MAXIMUM FAULT CURRENTS:**

- System SC contribution at maximum available, supply voltage set to 1.1 p.u.
- 22kV-SWGR Feeder A available and in-feed breaker is closed
- 22kV-SWGR Feeder B unavailable and in-feed breaker open
- 400V-LdCntr Tie-Breaker closed, "CB A" in-feed breaker closed and "CB B" in-feed breaker open
- Motor contributions are included
- Cable resistances adjusted for the temperature of 20° C
- All loads are running on normal plus the largest stand by motor for CO2 Product Sendout Pump B is running

#### **4.2 CASE 2: MINIMUM FAULT CURRENTS:**

- System SC contribution at minimum available, supply voltage set to 0.95 p.u.
- 22kV-SWGR Feeder A available and in-feed breaker is closed
- 22kV-SWGR Feeder B unavailable and in-feed breaker open
- 400V-LdCntr Tie-Breaker open and both in-feed breakers closed
- Cable resistances adjusted for temperature 80° C
- Only Maintenance Loads are running on normal



## CALCULATION SHEET

Project: Karslo

Subject: Short-Circuit Calculations

Job Number: 25474

Calculation No: 25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 7

Sheet Rev. 0

### 4.3 RESULTS OF THE CALCULATIONS:

- Reports and SLDs with Calculations Results for 3-phase symmetrical fault and line-to-line, line-to-earth, line-to-line-to-earth are in the 6.0 Attachments.
- The Summary of results of each case for 3-phase symmetrical fault on main busses and at the ends of selected cables is listed in the following table:

#### Short Circuit Study Results

Bus Name	Bus Voltage (kV)	Bus SC Rating RMS/Pk Steady/ MaxPeak (kA)	SC Case 1			Spare SC Capacity RMS/Pk Steady/ MaxPeak (kA)	SC Case 2			Spare SC Capacity RMS/Pk Steady/ MaxPeak (kA)
			Current				Current			
			Max Peak (kA)	Sub-T RMS (kA)	Steady RMS (kA)		Max Peak (kA)	Sub-T RMS (kA)	Steady RMS (kA)	
22kV-SWGR	22	31.5/80	31.9	12.09	10.46	21/48	21.27	7.95	7.74	23/58
6.6kV-SWGR	6.6	31.5/80	45.9	18.16	12.06	19/34	N/A	N/A	N/A	N/A
400V-LdCntr-1	0.4	100/220	169.9	74.14	59.8	40/50	119.13	51.31	44.4	55/100
400V-LdCntr-2	0.4	100/220	169.9	74.14	59.9	40/50	115.9	49.75	44.4	55/104
400V-MCC-1	0.4	75/165	139.7	64.5	52.5	22/25	100.18	45.99	39.53	35/64
400V-MCC-2	0.4	75/165	138.8	64.15	52.5	22/26	97.32	44.5	39.53	35/67
400V-EssMCC	0.4	75/165	135.2	62.0	51.4	23/29	95.0	43.19	38.84	36/70
Cable C-StDwnTr (B-StpDwnTr)	(22)	(80)	31.72	12.05	10.4	N/A	N/A	N/A	N/A	N/A
Cable C-CmprsrTr (B-CmprsrTr)	(22)	(80)	31.39	11.99	10.4	N/A	N/A	N/A	N/A	N/A
Cable C-LAmin.A (B-LAmin.A)	(6.6)	(80)	35.85	16.76	11.44	N/A	N/A	N/A	N/A	N/A
Cable C-RAmin.1A (B-RAmin.1A)	(6.6)	(80)	34.75	16.55	11.35	N/A	N/A	N/A	N/A	N/A

In the table above:

- SC spare capacity is calculated as (Bus rated steady/max peak current) - (Bus calculated steady/max peak current) respectively for particular bus system.



## CALCULATION SHEET

Project: Karsto

Job Number: 25474

Subject: Short-Circuit Calculations

Calculation No 25474-000-E0C-ES-00002

By: Victor Skavitine

Date: 11/21/08

Sheet No. : 8

Sheet Rev. 0

### **5.0 CONCLUSIONS**

The calculations in this Report are based on assumed data and therefore it is considered as preliminary calculations only. At this stage, the results are adequate for equipment sizing. For the next phase of the project these calculations should be revisited when more information on equipment and the system is available.

- The switchgear (SWGR) and motor control centers (MCC) are standard type equipment.
- Chosen SC current rating of equipment has ample spare capacity for future loads.

### **6.0 LIST OF ATTACHMENTS**

#### **6.1 INPUT DATA**

- Attachment 1, Input Data, SLD, 1 page.

#### **6.2 SHORT-CIRCUIT CALCULATIONS REPORTS AND SINGLE LINE DIAGRAMS**

- Attachment 2, SC Case 1, Results on SLD, 1 page; Summary Report for 3-Phase Fault currents and Equipment evaluations, 3 pages.
- Attachment 3, SC Case 1, L-L-E – Results on SLD, 1 page; Summary Report for 3-Phase, Line-Ground, Line-Line, Line-Line-Ground Fault currents, 2 pages
- Attachment 4, SC Case 2, 3-phase results on SLD, 1 page; Summary Report for 3-Phase, Line-Ground, Line-Line, Line-Line-Ground Fault currents, 2 pages.
- Attachment 5, SC Case 2, L-L-E results on SLD, 1 page;





# CALCULATION SHEET

Project: Karsto

Job Number: 25474

Calculation No 25474-000-E0C-ES-00002

Subject: Short-Circuit Calculations

By: Victor Skavtine


Date: 11/21/08

Sheet No. : 9


Sheet Rev. 0

## ATTACHMENTS

CO2 KARSTO  
 ONE LINE DIAGRAM  
 INPUT DATA



CO2 KARSTO  
 ONE LINE DIAGRAM  
 Short-Circuit Calculations  
 Case 1



Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C  
Study Case: SC Case1RevA

Page: 1  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config.: UmaxLmaxC1.1

Preliminary Design

**Short-Circuit Summary Report**

3-Phase Fault Currents

Bus		Device		Device Capacity (kA)				Short-Circuit Current (kA)					
ID	kV	ID	Type	Making Peak	Ib sym	Ib asym	Idc	I <sup>pk</sup>	ip	Ib sym	Ib asym	Idc	Ik
6.6kV-SWGR	6.600	6.6kV-SWGR	SwchGear	80.000				18.160	45.909				12.058
	6.600	CB8	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB21	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB22	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB23	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB24	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB25	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB26	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB27	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB28	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB29	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB30	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB31	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB32	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB33	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB34	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
	6.600	CB35	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973	
6.600	CB53	CB	80.000	31.500	34.482	14.027	18.160	45.909	15.775	18.148	8.973		
22kV-SWGR	22.000	22kV-SWGR	SwchGear	80.000				12.092	31.920				10.459
	22.000	CB1	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
	22.000	CB3	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
	22.000	CB4	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
	22.000	CB5	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
	22.000	CB6	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
	22.000	CB7	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
	22.000	CB10	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515	
22.000	CB11	CB	80.000	31.500	33.206	10.508	12.092	31.920	11.553	13.782	7.515		
400V-EssMCC	0.400	400V-EssMCC	MCC	165.000				62.004	135.226				51.404
	0.400	CB47	CB	165.000	75.000	76.583		62.004	135.226	59.671	61.343	14.221	
	0.400	CB50	CB	165.000	75.000	76.583		62.004	135.226	59.671	61.343	14.221	
	0.400	CB61	CB	165.000	75.000	76.583		62.004	135.226	59.671	61.343	14.221	
400V-LdCntr-I	0.400	400V-LdCntr-I	SwchGear	220.000				74.136	169.882				59.855
	0.400	CB A	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB14	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB38	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	

Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C  
Study Case: SC Case1RevA

Page: 2  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config.: UmaxLmaxC1.1

Preliminary Design

3-Phase Fault Currents

Bus		Device		Device Capacity (kA)				Short-Circuit Current (kA)					
ID	kV	ID	Type	Making Peak	Ib sym	Ib asym	Idc	I''k	ip	Ib sym	Ib asym	Idc	Ik
400V-LdCntr-1	0.400	CB75	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB59	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
400V-LdCntr-2	0.400	400V-LdCntr-2	SwthGear	220.000				74.136	169.882				59.855
	0.400	CB14	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB19	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB40	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB76	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
	0.400	CB82	CB	220.000	100.000	100.000		74.136	169.882	67.167	67.180	1.340	
400V-MCC-1	0.400	400V-MCC-1	MCC	165.000				64.520	139.654				52.463
	0.400	CB78	CB	165.000	75.000	75.000		64.520	139.654	58.721	58.721	0.199	
400V-MCC-2	0.400	400V-MCC-2	MCC	165.000				64.151	138.816				52.463
	0.400	CB77	CB	165.000	75.000	75.000		64.151	138.816	58.618	58.619	0.198	
B-CmprsTr	22.000	B-CmprsTr	Cable Bus	80.000				11.987	31.386				10.381
B-LAmin.A	6.600	B-LAmin.A	MCC	80.000				16.763	35.851				11.443
B-RAmin.1A	6.600	B-RAmin.1A	MCC	80.000				16.554	34.750				11.350
B-StpDwnTr	22.000	B-StpDwnTr	Cable Bus	80.000				12.055	31.725				10.423
Feeder A	20.000	Feeder A	Bus					131.717	366.109				130.000
Feeder B	6.600	Feeder B	Bus					25.000	68.693				25.000

ip is calculated using method C

Ib does not include decay of non-terminal faulted induction motors

Ik is the maximum steady state fault current

Idc is based on X/R from Method C and Ib as specified above

LV CB duty determined based on service rating.

Total through current is used for device duty.

\* Indicates a device with calculated duty exceeding the device capability.

# Indicates a device with calculated duty exceeding the device marginal limit. ( 95 % times device capability)

Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C

Study Case: SC Case1RevA

Page: 3  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config.: UmaxLmaxC1.1

Preliminary Design

**Short-Circuit Summary Report**


Bus ID	Device ID	Device Capacity		3-Phase Short-Circuit Current
		I <sub>thr</sub> (kA)	T <sub>kr</sub> (sec.)	I <sub>th</sub> (kA)
400V-EssMCC	CB47	75.000	1.00	58.123
400V-EssMCC	CB50	75.000	1.00	58.123
400V-EssMCC	CB61	75.000	1.00	58.123
400V-LdCntr-1	CB A	75.000	1.00	69.184
400V-LdCntr-1	CB14	75.000	1.00	69.184
400V-LdCntr-1	CB38	75.000	1.00	69.184
400V-LdCntr-1	CB75	75.000	1.00	69.184
400V-LdCntr-1	CB59	75.000	1.00	69.184
400V-LdCntr-2	CB14	75.000	1.00	69.184
400V-LdCntr-2	CB19	75.000	1.00	69.184
400V-LdCntr-2	CB40	75.000	1.00	69.184
400V-LdCntr-2	CB76	75.000	1.00	69.184
400V-LdCntr-2	CB82	75.000	1.00	69.184
400V-MCC-1	CB78	75.000	1.00	60.147
400V-MCC-2	CB77	75.000	1.00	59.896

I<sub>thr</sub> = Rated short-circuit withstand current  
T<sub>kr</sub> = Rated short-time  
I<sub>th</sub> = Thermal equivalent short-time current

\* Indicates a device with calculated duty exceeding the device capability.

# Indicates a device with calculated duty exceeding the device marginal limit. ( 95 % times device capability)

**CO2 KARSTO  
 ONE LINE DIAGRAM  
 Short-Circuit Calculations  
 Case 1(L-L-Earth)**



Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C

Study Case: SC Case1RevA

Page: 1  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config.: UmaxLmaxC1.1

Preliminary Design

**Short-Circuit Summary Report**

3-Phase, LG, LL, LLG Fault Currents

Bus ID	kV	3-Phase Fault			Line-to-Ground Fault				Line-to-Line Fault				* Line-to-Line-to-Ground			
		I <sup>''</sup> k	ip	Ik	I <sup>''</sup> k	ip	Ib	Ik	I <sup>''</sup> k	ip	Ib	Ik	I <sup>''</sup> k	ip	Ib	Ik
6.6kV-SWGR	6.600	18.160	45.909	12.058	0.000	0.000	0.000	0.000	15.801	39.945	15.801	15.801	15.801	39.945	15.801	15.801
22kV-SWGR	22.000	12.092	31.920	10.459	0.000	0.000	0.000	0.000	10.483	27.672	10.483	10.483	10.483	27.672	10.483	10.483
400V-EssMCC	0.400	62.004	135.226	51.404	55.631	121.328	55.631	55.631	53.559	116.809	53.559	53.559	59.865	130.563	59.865	59.865
400V-LdCntr-1	0.400	74.136	169.882	59.855	71.526	163.901	71.526	71.526	64.001	146.658	64.001	64.001	73.607	168.669	73.607	73.607
400V-LdCntr-2	0.400	74.136	169.882	59.855	71.526	163.901	71.526	71.526	64.001	146.658	64.001	64.001	73.607	168.669	73.607	73.607
400V-MCC-1	0.400	64.520	139.654	52.463	57.846	125.208	57.846	57.846	55.729	120.628	55.729	55.729	62.205	134.644	62.205	62.205
400V-MCC-2	0.400	64.151	138.816	52.463	57.648	124.742	57.648	57.648	55.411	119.904	55.411	55.411	61.907	133.959	61.907	61.907
B-CmprsrTr	22.000	11.987	31.386	10.381	0.000	0.000	0.000	0.000	10.392	27.209	10.392	10.392	10.392	27.209	10.392	10.392
B-LAmin.A	6.600	16.763	35.851	11.443	0.000	0.000	0.000	0.000	14.576	31.174	14.576	14.576	14.576	31.174	14.576	14.576
B-RAmin.1A	6.600	16.554	34.750	11.350	0.000	0.000	0.000	0.000	14.393	30.213	14.393	14.393	14.393	30.213	14.393	14.393
B-StpDwnTr	22.000	12.055	31.725	10.423	0.000	0.000	0.000	0.000	10.451	27.503	10.451	10.451	10.451	27.503	10.451	10.451
Feeder A	20.000	131.717	366.109	130.000	131.706	366.079	131.706	131.706	114.080	317.087	114.080	114.080	131.778	366.278	131.778	131.778
Feeder B	6.600	25.000	68.693	25.000	25.085	68.927	25.085	25.085	21.651	59.490	21.651	21.651	25.043	68.811	25.043	25.043

All fault currents are in rms kA. Current ip is calculated using Method C.

\* LLG fault current is the larger of the two faulted line currents.



Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C  
Study Case: SC Case1RevA


Page: 2  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config: UmaxLmaxC1.1

Preliminary Design

**Sequence Impedance Summary Report**

Bus		Positive Seq. Imp. (ohm)			Negative Seq. Imp. (ohm)			Zero Seq. Imp. (ohm)			Fault Zf (ohm)		
ID	kV	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance
6.6kV-SWGR	6.600	0.01950	0.22998	0.23081	0.01977	0.22780	0.22865				0.00000	0.00000	0.00000
22kV-SWGR	22.000	0.05950	1.15389	1.15542	0.05971	1.15151	1.15306				0.00000	0.00000	0.00000
400V-EssMCC	0.400	0.00090	0.00400	0.00410	0.00089	0.00402	0.00412	0.00100	0.00539	0.00549	0.00000	0.00000	0.00000
400V-LdCntr-1	0.400	0.00060	0.00337	0.00343	0.00060	0.00340	0.00345	0.00053	0.00374	0.00378	0.00000	0.00000	0.00000
400V-LdCntr-2	0.400	0.00060	0.00337	0.00343	0.00060	0.00340	0.00345	0.00053	0.00374	0.00378	0.00000	0.00000	0.00000
400V-MCC-1	0.400	0.00089	0.00384	0.00394	0.00088	0.00386	0.00396	0.00102	0.00518	0.00528	0.00000	0.00000	0.00000
400V-MCC-2	0.400	0.00089	0.00386	0.00396	0.00089	0.00388	0.00398	0.00102	0.00518	0.00528	0.00000	0.00000	0.00000
B-CmprsrTr	22.000	0.06703	1.16364	1.16557	0.06724	1.16126	1.16321				0.00000	0.00000	0.00000
B-LAmin.A	6.600	0.05715	0.24343	0.25004	0.05747	0.24127	0.24802				0.00000	0.00000	0.00000
B-RAmin.1A	6.600	0.06249	0.24538	0.25321	0.06283	0.24322	0.25121				0.00000	0.00000	0.00000
B-StpDwnTr	22.000	0.06227	1.15730	1.15898	0.06246	1.15490	1.15659				0.00000	0.00000	0.00000
Feeder A	20.000	0.00118	0.09642	0.09643	0.00118	0.09641	0.09642	0.00102	0.09647	0.09647	0.00000	0.00000	0.00000
Feeder B	6.600	0.00335	0.16763	0.16766	0.00335	0.16763	0.16766	0.00332	0.16592	0.16595	0.00000	0.00000	0.00000

**CO2 KARSTO  
 ONE LINE DIAGRAM  
 Short-Circuit Calculations  
 Case 2 (3-phase)**



Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C  
Study Case: SC Case2RevA

Page: 1  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config.: UminLminC.95

Preliminary Design

**Short-Circuit Summary Report**

3-Phase, LG, LL, LLLG Fault Currents

Bus ID	kV	3-Phase Fault			Line-to-Ground Fault				Line-to-Line Fault				*Line-to-Line-to-Ground			
		I <sup>"k</sup>	ip	Ik	I <sup>"k</sup>	ip	Ib	Ik	I <sup>"k</sup>	ip	Ib	Ik	I <sup>"k</sup>	ip	Ib	Ik
22kV-SWGR	22.000	7.954	21.270	7.742	0.000	0.000	0.000	0.000	6.885	18.412	6.885	6.885	6.885	18.412	6.885	6.885
400V-EssMCC	0.400	43.187	95.011	38.837	40.467	89.027	40.467	40.467	37.373	82.220	37.373	37.373	42.091	92.600	42.091	42.091
400V-LdCntr-1	0.400	51.310	119.134	44.412	50.796	117.940	50.796	50.796	44.260	102.763	44.260	44.260	51.320	119.157	51.320	51.320
400V-LdCntr-2	0.400	49.746	115.927	44.412	49.861	116.196	49.861	49.861	43.042	100.305	43.042	43.042	50.051	116.638	50.051	50.051
400V-MCC-1	0.400	45.991	100.184	39.529	42.555	92.699	42.555	42.555	39.696	86.470	39.696	39.696	44.520	96.978	44.520	44.520
400V-MCC-2	0.400	44.502	97.321	39.529	41.760	91.324	41.760	41.760	38.511	84.219	38.511	38.511	43.319	94.733	43.319	43.319
Feeder A	20.000	60.247	167.593	60.000	73.578	204.676	73.578	73.578	52.172	145.129	52.172	52.172	70.412	195.870	70.412	70.412
Feeder B	6.600	8.000	21.982	8.000	10.351	28.441	10.351	10.351	6.928	19.037	6.928	6.928	10.086	27.712	10.086	10.086

All fault currents are in rms kA. Current ip is calculated using Method C.

\* LLLG fault current is the larger of the two faulted line currents.

Project: CO2 Karsto  
Location: Karsto, South-West of Norway  
Contract: Bechtel 25474  
Engineer: Victor Skavitine  
Filename: KARSTO

ETAP  
6.0.0C

Study Case: SC Case2RevA

Page: 2  
Date: 19-11-2008  
SN: BANTRELENG  
Revision: Base  
Config.: UminLminC.95

Preliminary Design

**Sequence Impedance Summary Report**

Bus		Positive Seq. Imp. (ohm)			Negative Seq. Imp. (ohm)			Zero Seq. Imp. (ohm)			Fault Zf (ohm)		
ID	kV	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance
22kV-SWGR	22.000	0.06823	1.59545	1.59691	0.06744	1.59699	1.59841				0.00000	0.00000	0.00000
400V-EssMCC	0.400	0.00105	0.00497	0.00508	0.00105	0.00498	0.00509	0.00119	0.00598	0.00610	0.00000	0.00000	0.00000
400V-LdCntr-1	0.400	0.00069	0.00422	0.00428	0.00068	0.00426	0.00431	0.00061	0.00433	0.00437	0.00000	0.00000	0.00000
400V-LdCntr-2	0.400	0.00070	0.00436	0.00441	0.00069	0.00436	0.00442	0.00061	0.00433	0.00437	0.00000	0.00000	0.00000
400V-MCC-1	0.400	0.00103	0.00466	0.00477	0.00102	0.00469	0.00480	0.00122	0.00577	0.00589	0.00000	0.00000	0.00000
400V-MCC-2	0.400	0.00104	0.00482	0.00493	0.00104	0.00483	0.00494	0.00122	0.00577	0.00589	0.00000	0.00000	0.00000
Feeder A	20.000	0.00229	0.19165	0.19166	0.00228	0.19167	0.19169	0.00092	0.08745	0.08746	0.00000	0.00000	0.00000
Feeder B	6.600	0.00952	0.47622	0.47631	0.00952	0.47622	0.47631	0.00303	0.15174	0.15177	0.00000	0.00000	0.00000

CO2 KARSTO  
 ONE LINE DIAGRAM  
 Short-Circuit Calculations  
 Case 2 (L-L-Earth)

